



This is an electronic reprint of the original article. This reprint may differ from the original in pagination and typographic detail.

Ju, Yuchen; Hiltunen, Pauli; Jokisalo, Juha; Kosonen, Risto; Syri, Sanna

Benefits through Space Heating and Thermal Storage with Demand Response Control for a District-Heated Office Building

Published in: Buildings

DOI: 10.3390/buildings13102670

Published: 01/10/2023

Document Version Publisher's PDF, also known as Version of record

Published under the following license: CC BY

Please cite the original version:

Ju, Y., Hiltunen, P., Jokisalo, J., Kosonen, R., & Syri, S. (2023). Benefits through Space Heating and Thermal Storage with Demand Response Control for a District-Heated Office Building. *Buildings*, *13*(10), Article 2670. https://doi.org/10.3390/buildings13102670

This material is protected by copyright and other intellectual property rights, and duplication or sale of all or part of any of the repository collections is not permitted, except that material may be duplicated by you for your research use or educational purposes in electronic or print form. You must obtain permission for any other use. Electronic or print copies may not be offered, whether for sale or otherwise to anyone who is not an authorised user.





Article Benefits through Space Heating and Thermal Storage with Demand Response Control for a District-Heated Office Building

Yuchen Ju^{1,2,*}, Pauli Hiltunen^{1,2}, Juha Jokisalo^{1,2}, Risto Kosonen^{1,2,3}, and Sanna Syri^{1,2}

- ¹ Department of Mechanical Engineering, Aalto University, 02150 Espoo, Finland; pauli.m.hiltunen@aalto.fi (P.H.); juha.jokisalo@aalto.fi (J.J.); risto.kosonen@aalto.fi (R.K.); sanna.syri@aalto.fi (S.S.)
- ² Smart City Center of Excellence, TalTech, 19086 Tallinn, Estonia
- ³ College of Urban Construction, Nanjing Tech University, Nanjing 210037, China
 - Correspondence: yuchen.ju@aalto.fi

Abstract: Demand response techniques can be effective at reducing heating costs for building owners. However, few studies have considered the dynamic marginal costs for district heating production and taken advantage of them for building-level demand response. In this study, a district heating network in the Finnish city of Espoo was modeled to define dynamic district heat prices. The benefits of two demand response control approaches for a Finnish office building, the demand response control of space heating and a thermal energy storage tank, were evaluated by comparing them to each other and utilizing them together. A 5 m^3 storage tank was installed in a substation of a conventional high-temperature district heating network. A new demand response control strategy was designed to make the most of the storage tank capacity, considering dynamic district heat prices and the maximum allowed return water temperature. The results indicate that the demand response control of space heating and the storage tank cut district heat energy costs by 9.6% and 3.4%, respectively. When employing the two approaches simultaneously, 12.8% savings of district heat energy costs were attained. Additionally, thermal energy storage provides more potential for peak power limiting. The maximum heating power decreases by 43% and the power fee reduces by 41.2%. Therefore, the total cost, including the district heat energy cost and the power fee, can be cut up to 22.4% without compromising thermal comfort and heat supply temperatures to ventilation systems.

Keywords: thermal energy storage; district heating; demand response

1. Introduction

District heat is the most common source of space heating in Finland. In 2020, it covered 45% of the market share of space heating for residential, commercial, and public buildings [1]. In 2021, 54% of residential buildings, 58% of commercial buildings, and 84% of public buildings were connected to district heating (DH) networks [1]. Since the aim in Finland is to be carbon neutral by 2035 [2], strategies for the decarbonization of the energy sector and for energy efficiency improvements in the building sector should be developed simultaneously.

Demand-side management is the approach of adjusting consumer demand curves to follow energy generation patterns [3]. Usually, demand response (DR) encourages consumers to use more energy during off-peak hours so that peak power demand decreases. Consumers can gain monetary benefits through DR. Moreover, is the resulting peak power reduction can improve energy systems' reliability and efficiency [4]. Therefore, this promotes further research on buildings' energy demand adjustment potential by demand response to match energy supply to minimize energy costs and peak loads.

By utilizing available thermal energy storage (TES), such as buildings' thermal mass and thermal energy storage tanks, demand response strategies could be applied to building energy systems for reducing peak power and load shifting. Usually, based on dynamic electricity prices, higher indoor air temperature setpoints are defined so that heat is stored



Citation: Ju, Y.; Hiltunen, P.; Jokisalo, J.; Kosonen, R.; Syri, S. Benefits through Space Heating and Thermal Storage with Demand Response Control for a District-Heated Office Building. *Buildings* **2023**, *13*, 2670. https://doi.org/10.3390/ buildings13102670

Academic Editor: Kian Jon Chua

Received: 19 August 2023 Revised: 20 October 2023 Accepted: 20 October 2023 Published: 23 October 2023



Copyright: © 2023 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (https:// creativecommons.org/licenses/by/ 4.0/). in a building's thermal mass during low-price periods. Indoor air temperature decreases for discharging when the energy price is high [5,6]. Recently, cases focused on district-heated buildings and their connected DH grids have increased. Hedegaard et al. established [7] a model with 159 single-family houses to examine the effectiveness of price-based demand response control by utilizing buildings' thermal mass storage to reduce district heating peaks. Dominković et al. [8] found that using thermal mass for storage provided 5.5–7.7% of flexible load regarding total DH demand. Furthermore, more solar thermal heating energy could be effectively exploited in the DH system.

For short-term TES, because of its low cost, technological simplicity, thermal characteristics, and other advantages, sensible heat TES using water as a medium offers a wide range of applications [9]. In DH systems, short-term TES has usually been integrated with CHPs for production optimization [9,10]. Jebamalai et al. [11] found that this resulted in greater cost reductions for a DH network by centralized storage with lower daily peak fluctuations, whereas storage installed in substations was better suited for more varied daily peak profiles. What is more, mixed-integer linear programming (MILP) or EnergyPro software was one method utilized for the optimization of energy generation components among various candidates [12,13]. Benalcazar [14] evaluated the most appropriate TES capacity in CHP systems. It decreased peak power demand and reduced heat-only boilers' fuel costs. Tan et al. [15] took arbitrage in electricity and reserve markets into consideration. They developed an economic approach for a DH system which cut operational expenses, total investment, and peak load by TES.

In addition, scholars have begun to pay attention to DH markets. The heat merit order method was presented to calculate the marginal costs of DH production for bidding and wholesale [16,17]. Liu et al. [18] analyzed three DH production mixes in Netherlands. They found that low-carbon heat generation technologies tend to have low short-run marginal costs.

Demand response benefits can also be gained when short-term TES is installed in DH substations. Cai et al. [19] proposed a demand response control strategy based on DH marginal costs and adjusting buildings' indoor air temperatures and DHW tanks' temperatures of all substations in a DH network. The maximum DH supply water temperature was 95 °C. Although it decreased the total DH cost, the peak heating power increased.

In ultra- or low-temperature DH systems, the designed DH supply temperature can be as low as 40 °C [20]. However, for hygiene purpose, the DHW supply temperature should be high enough to inhibit the growth of legionella bacteria [21]. For example, in Finland, the DHW temperature in a system must be at least 55 °C [22]. Therefore, to guarantee the required DHW temperature level, short-term TES was installed in the study building and heated by heat pumps or electric heaters. The preheating strategy was designed considering PV generation potential, dynamic electricity prices, electricity load, etc. Buffa et al. [23] have offered solutions for improving the operation of DHW thermal storage systems by demand response. Similarly, Knudsen and Petersen [24] investigated the way in which a heat pump in an ultra-low temperature DH network for DHW heating was utilized to reduce peaks and save energy costs by demand response. It indicated that the presented control saved costs by about 5% per year and shifted loads to off-peak periods without sacrificing hygiene and thermal comfort.

Based on the references mentioned above, studies mainly analyzed the marginal costs trading of the DH market or demand response benefits for DH production by utilizing marginal costs. Therefore, the gap in the knowledge is that few studies have taken advantage of calculating dynamic district heat prices for building-level demand response. In addition, short-term thermal storage systems installed in DH substations were usually connected to ultra- or low-temperature DH networks with heat pumps or other units. Therefore, according to the authors' best knowledge, this is the first study to analyze demand response benefits for building owners with a short-term thermal storage tank integrated into a DH substation in a conventional high-temperature DH network. In this study, a DH network was modeled to calculate the marginal costs for defining dynamic district heat

Therefore, according to the authors' best knowledge, this is the first study to analyze demand response benefits for building owners with a short-term thermal storage tank integrated into a DH substation in a conventional high-temperature DH network. In this study, a DH network was modeled to calculate the marginal costs for defining dygamic district heat prices. The benefits of the two demand response control approaches, demand response control of space heating, and the storage tankwere evaluated by comparing them to each other and utilizing them together. Moreover, this paper examined the peak power-Limitions population leafithe, storage took ge darkweined it with demondramporation to each other Interstation of a strategy of the second s bigentranperneuseo Albenative arkites huilding lovel demand response. The storage tank supplied heats for spaces had tangen with tions and a DEAW to a Binnight affice building e Thomas highentetanple tampe fattume twas rRO free. bTilkling x terraindet mange rapparitye. W The d Z Took & Ya, twitch a semplications divises a constraint in the second nity in History of the second second state of the second state of the second second second states and the second a comperaturendifference on 30 control to the stanky variable signed to Belkeetteerkoist the Hierdia age catyle as a comparation of the second s rentrol wademendresponse rootral strategresses desigond to make the make the source of state or againg tank capacity countidering dynamic district beat prices and the papeimum allowed section tatury water temperature is inverse of the provided by the control and the states space the plane power for the building lavel storage tank, were applied in this paper. The results section analyzes in the paper were the power tee, demand response the energy flexibility provided by them. In addition, it discusses the peak power limiting benefits, thermal comfort, and the building level thermal storage tank temperature, potential of the storage tank and its impacts on the power fee, demand response benefits, thermal comfort, and the building-level thermal storage tank temperature. 2. Methodology

2. Methisdulogyn includes three parts. Firstly, Section 2.1 presents the whole simulation processis setter that we set on ree 2 ints our say Decision during the modeling mothordcess system this tige heat prisar and convertionally, the kuilding terrelationlation another solution and the solution of th sensu Aliorupstation ils vous the Succidation. tothere a recent less date item and as spondingenpartalevent and the second spofmetoon trol algorithms for space heating and the building-level storage tank, and energy flexibility factors.



Figure 1. Description of the simulation process. Figure 1. Description of the simulation process.

For the first step, a DH production mix with a centralized TES in the network of Espoo show Fornt Sections stop and principation mixiginal costs marginal solution in the principal stop in the princ eose exprodice Sectionst 2.2.2. wa Deptimized to consectional produce Marsinal, cent is a defined as the neghterproduce that with draft the produce the second state of the produce of svitlenthanaighosteameration theory is the sonarthet which is a charaction is the faster of the sonarthe the for simulating energy systems combining heat and electricity markets [26]. It optimized the running order of the different production units according to their production costs. Following that, dynamic district heat prices were calculated as shown in step 2. Demand response control signals were designed according to the prices in step 3. The two demand response control approaches were applied for decreasing the office building's DH energy

costs. Moreover, the peak power limiting potential provided by the building-level storage tank was fully utilized to reduce power fee of the building owners.

2.2. DH Production

2.2.1. DH Network Modeling

This section includes three parts. The first paragraph briefly introduces the parameters considered in the modeling process, such as distribution costs, electricity prices, taxes, etc. The second paragraph explains the way in which the modeling period was defined and selected for analysis. The last describes the assumptions made for the heat demand of the model. The production mixes of the DH system are shown in Section 2.2.2.

In this study, hourly district heat prices were established based on an actual DH network in Espoo. The DH system was modeled to simulate the hourly DH marginal production costs. Hourly dynamic prices were generated from the results of the model. In this study, only the variable costs of DH production and distribution were considered, which include fuel costs, fuel taxes, CO₂ allowances, electricity purchases and distribution, tax, variable operation, and maintenance costs of the production units. Electricity was purchased from the spot market, and the spot price was collected from Nordpool historical data for the period from 10 January 2021 to 30 September 2022 [27]. Combined heat and power (CHP) units also sold electricity to the spot market, and the revenues are subtracted from the production costs. Heat demand, the electricity demand of pumping, electricity price and distribution price, supply and return temperatures of the network, price of CO₂ allowances, and the inlet and outlet temperatures of sewage water to the heat pumps (HP) were inputted to the model as time series.

In this study, the data and outdoor temperature statistics of 2019 were used to estimate the total heat demand and heat losses of the period from 1 October 2021 to 30 September 2022. The data of 2019 were the latest available statistics from the database [28]. This modeling period, 10 January 2021 to 30 September 2022, showed the price properties after the energy crisis, and the time resolution is one hour. Since demand response benefits incurred by controlling the space heating and the hot water storage tank of the building were analyzed, only the heating season data (from 10 January 2021 to 30 April 2022) were selected to be included this study.

In 2019, the heat demand of the Espoo DH network was 2141 GWh, and distribution losses were 230 GWh [28]. It was assumed that 70% of the total DH demand in 2019 was annual space heating demand [29]. Thus, the annual space heating demand was 1499 GWh, and the rest of the DHW demand was 642 GWh. The annual space heating demand is dependent on heating degree hours. Heating degree hours were counted for 2019 using a 24-h moving average of outdoor temperature. If it was more than 12 °C, the annual space heating demand and heating degree hours were assumed to be zero. If the 24-h moving average of outdoor temperature was lower than 12 °C, the heating degree hours were equal to the difference between the 24-h moving average of outdoor temperature and the indoor air temperature, 17 °C [30]. For 2019, the heating degree-hours were 85,307 °Ch, which gives a specific value of 17.6 MWh/°Ch for the annual space heating demand. The heating degree hours for the period from 10 January 2021 to 30 September 2022 were 91,570 °Ch. Therefore, the annual space heating demand for this period was estimated to be 1609 GWh. The DHW demand was assumed to be equal to the demand of 2019. Similarly, the total distribution heat losses for the studied period were estimated to be 247 GWh. Thus, the annual space heating demand was divided into every hour of the studied period based on the specific value of 17.6 MWh/ $^{\circ}$ Ch and hourly heating degree hours. The total annual DHW demand was 642 GWh, as mentioned above. Therefore, the hourly DHW demand was assumed to be a constant value, 73 MW.

2.2.2. Simulated DH System

The DH system consists of three CHP units, several heat-only boilers (HOB), heat pumps (HP) utilizing the waste heat of sewage water, and a centralized TES unit. The

capacity of the 20,000 m³ hot water storage is 858 MWh, with stratification considered. Thus, the temperature was assumed to be 87 °C in the top part of the storage and 50 °C in the bottom. The thermal losses of the storage were not taken into account. The CHP units and the HP can charge the TES. Multiple HOBs combusting the same fuel were modeled as one unit. The two HP units utilizing the waste heat of sewage water were modeled as a single HP, and the software calculated its coefficient of performance (COP) every hour according to the design parameters, the supply and return temperatures of DH, and the inlet and outlet temperatures of sewage water. The design parameters of the HP and COP are presented in Table 1. A more detailed calculation method for the COP can be found in [31].

Table 1. HP design parameters [32].

Cupacity (1/1/1) = reinpermutate (C) = reinpermutate (C) = (°C) = (°C)	Capacity (MW)
47 65 50 14 7 3.7	47

The production units with their technical parameters are presented in Table 2. Fuel capacity is the maximum design amount of fuel used to generate heat or electricity. For example, at maximum load, CHP 1 consumed fuel equal to 265 MW to produce 160 MW of heat and 80 MW of electricity, considering losses.

Table 2. The list of production units and their technical parameters.

Unit	Fuel Type	Fuel Capacity (MW)	Generated Heat (MW)	Generated Electricity (MW)
CHP 1	Coal	265	160	80
CHP 2	Natural gas	498	214	234
CHP 3	Natural gas	132	75	45
Heat-only boiler (HOB) 1	Natural gas	496	446	-
Heat-only boiler (HOB) 2	Light fuel oil	94	85	-
Heat-only boiler (HOB) 3	Wood pellet	90	80	-
Heat-only boiler (HOB) 4	Bio oil	98	90	-
Heat-only boiler (HOB) 5	Wood chip	49	52	-
Heat pump (HP)	-	-	47	-

The utilization factors were calculated based on merit order modeling of these units. The largest share of DH was produced in the coal-fired CHP 1. The utilization factor is 66%, and it was operated mainly during winter. The wood chip-fired HOB 5 ran throughout almost the entire year with a utilization factor of 88%. However, due to the lower capacity, the annual share of production was lower than with the coal-fired CHP plant. The sewage water HP, wood pellet HOB, and bio-oil-fired HOB (HOB 3 and HOB 4) had utilization factors of 74%, 66%, and 49%. Because of the high prices of natural gas, the gas-fired HOB was only utilized during the highest peak demand, with a utilization factor of 6.5%. The natural gas-fired CHPs 2 and 3 were used only if the electricity price was high enough.

Electricity was purchased from the spot market to feed the heat pumps and to meet the electricity demand of network pumping. Distribution fees, electricity tax, and a security of supply fee were also paid for the consumed electricity. The distribution fees consist of the energy fee and the load fee. The energy fee of distribution was 9.91 €/MWh during winter days, and 3.29 €/MWh at other times. CHP plants sold electricity to the spot market. Plants selling electricity must also pay the load fee. Distribution fees were selected based on to the 2021 high-voltage network pricing of the distribution network [33]. The electricity costs are presented in Table 3.

Type of the Fee	Price (€/MWh)
Spot price	Average: 136.42
Distribution fee, winter days (7 a.m.–9 p.m., 1.12–28.2) [33]	9.91
Distribution fee, other time [33]	3.29
Electricity tax and security of supply fee (€/MWh)	22.53
Load fee, intake from the grid (€/MWh)	1.81
Load fee, output to the grid (€/MWh)	0.76

The production units that combusted fossil fuels paid emission allowances. The price of CO_2 allowances started rising rapidly in the spring of 2021, and the increased price had a significant impact on the costs of heat production based on fossil fuels. Therefore, monthly average CO_2 prices were used in the model [34]. For different fuels, fixed prices were applied, and the 2021 fuel tax fees were used in this study. For CHP units, only fuels for heat production are subject to fuel taxation, and they are subject to a deducted carbon dioxide tax. The fuel costs are collected in Table 4. The fuel prices were defined as the average price in Finland during the studied period.

Fuel Type	Fuel Price (€/MWh)Fuel Tax of Heat-Only Boiler (HOB) (€/MWh)Fuel Tax of CHP (€/MWh)		Fuel Tax of CHP (€/MWh)	Emission Factor [35] (ton _{CO2} /MWh)
Coal	22.81	32.00	24.34	0.335
Natural gas	97.13	23.35	15.72	0.199
Light fuel oil	149.78	30.21	-	0.255
Wood pellet	46.00	-	-	-
Wood chip	24.23	-	-	-
Bio oil	67.00	10.67	-	-

In the production costs, the variable maintenance costs of the different units were considered as well. The maintenance costs were $4.5 \notin /MWh$ of electricity production for CHP plants, $2 \notin /MWh$ of fuel consumption for HOBs, and $3 \notin /MWh$ of heat production for HP. All the costs are presented without value-added tax (VAT). The emissions factors were collected from Statistics Finland [35].

2.2.3. District Heat Prices

The production mix of each hour was acquired from the EnergyPRO model of the DH system. The dynamic DH pricing was based on the marginal production costs of the DH system. The marginal production cost was equal to the production cost of the most expensive production unit running each hour. If the production cost of the most expensive unit was negative, the marginal production costs were defined to be equal to zero. This could happen if electricity price was high enough, and all the heat demand could be met using the CHP plants. The pumping costs of the network were added to the marginal production costs, and the network losses were considered by dividing the marginal costs by the network efficiency.

To ensure that the DH company's annual revenues from selling heat with dynamic pricing are realistic, the marginal production costs were scaled so that the annual weighted average price was equal to that of a local DH producer [36].

The annual average marginal cost weighted by the heat demand was $88.49 \notin MWh$, and the actual annual average DH price of the local DH company weighted by heat demand was $58.91 \notin MWh$, approximately one-third lower. Therefore, the marginal costs of heat were multiplied by a factor of 0.6657. The calculation method of the dynamic DH price is presented in Equation (1), where p_{DH} is the hourly dynamic price of DH, $c_{produciton}$ is the

Table 3. Electricity costs.

pricing are realistic, the marginal production costs were scaled so that the annual weighted average price was equal to that of a local DH producer [36].

The annual average marginal cost weighted by the heat demand was $88.49 \notin MWh$, and the actual annual average DH price of the local DH company weighted by heat demand was $58.91 \notin MWh$, approximately one-third lower. Therefore, the marginal costs ofheat were multiplied by a factor of 0.6657. The calculation method of the dynamic DH price is presented in Equation (1), where *pDH* is the hourly dynamic price of DH, *cproduciton* is the hourly rharging in borodiocticost cost of the DHI metwork.

$$p_{DH} \stackrel{p_{0H6}}{=} \frac{p_{0H6}}{59} \cdot \frac{6657}{59} \cdot \frac{c_{production}}{\eta_{netv}} \frac{\times c_{pumping}}{\eta_{netv}}$$
(1)(1)

This study only analyzed the demand response benefits during the heating season. This study only analyzed the demand response benefits during the heating season. Therefore, the hourly DH prices with 24% VAT are shown in Figure 2. The maximum Therefore, the hourly DH prices with 24% VAT are shown in Figure 2. The maximum price vas 192.5 €/MWh, and the average price was 76.5 €/MWh. It was also found that (October Was 192.5 €/MWh, and the average price was 76.5 €/MWh. It was also found that (October (October 2021 to April 2022) higher electricity prices decreased the customer price during the heating season due to the increased revenues of the electricity sales of CHP units.



Higure 2. Dynamic district heat price with VAT244% duting the bestimperson.

22.2.4. Power Fee

Building owners in Finland need to pay powerfeed or district phetade buildings. Acccording to the power fee calculation method for public buildings (366 the power fee calculation method for public buildings).

$$\begin{cases} Power fee = 1.24 \times (62 \times P) - 60) \leq 9 \leq 980 \\ Power fee = 1.24 \times (53 \times P + 660) & 81 \leq P \leq 300 \\ Power fee = 1.24 \times (53 \times P + 660) & 81 \leq P \leq 300 \end{cases}$$
(2)

where *P* is the maximum heating power during the heating season, kW. The 24% VAT was where *P* is the maximum heating power during the heating season, kW. The 24% VAT was considered in this equation.

2.3. Building Level Simulation

2.3. Brilding Inthodiuted the demand response process of space heating and of the buildingleve Figure 8 tanks discuss the ignored proceeds and space heating and of the buildingithe Recent drage mark council as is a space of space beat of space heating and of the buildinging in the remainder of the proceeds of space beat of space heating and of the buildingthe series and desploy build the proceeds of space heating out the series of the ser

The demand response control process of the building-level storage tank considered the maximum allowed DH return water temperature (43 $^{\circ}$ C), the DHW temperature, and the minimum tank temperature setpoint. After that, they were combined to examine the benefits of the demand response control of space heating and the thermal storage tank.

Buildings 2023, 13, 2670

°C [38]. In addition, the setpoint smoothing technique was employed to prevent the rebound effect [39].

The demand response control process of the building-level storage tank considered the maximum allowed DH return water temperature (43 °C), the DHW temperature, and the minimum tank temperature setpoint. After that, they were combined to examine the benefits of the demand response control of space heating and the thermal storage tank.



Figure 3: Filow chart of the building-level simulation process.

2.3.1. Simulated Building

A typical Finnish office building in Espoo was selected for this study. Table Jifts the building parameters. The original construction period was in the early years of the 1980s, with several renovations after that. It was connected to a conventional high-temperature DH network. The building installed water radiators for space heating. The heat for DHW and the ventilation supply air was also covered by the DH network. Thus, the actual peak heating power demand during the heating season is the total maximum power including space fleating, ventilation, and DHW under the weather conditions of Espoo from October 2021 to April 2022 (see Section 2.3.3) with the basic DH substation (see Section 2.3.2). This DH power demand during the simulated heating season was used as the dimensioning DH power demand during the simulated heating season was used as the dimensioning DH power demand during the seating season was used as the dimensioning power of DH connection 1.3.2). This the basic DH substation (see Section 2.3.2). This power demand during the simulated heating season was used as the dimensioning DH power demand during the simulated heating season was used as the dimensioning power of DH connection in this study. Section 2.3.2 presents the heating system parameters power of DH connection in this study. Section 2.3.2 presents the heating system parameters.

Trable 5. Properties of the simulated office building.

Air leakage rate, h50 (1/h)	1.60
Usage time	8 a.m.–4 p.m. (workdays)
Annual internal heat gains of equipment (kWh/m ² ·a)	3.7
Annual internal heat gains of lighting (kWh/m ² ·a)	18.3
Actual peak heating power demand (kW)	113.2

The building U-values were selected following the Finnish building code of 1985 [40]. The building used triple-pane windows with a 9.5% area ratio of window to wall. The design indoor air temperature was set at 21 °C [41] during the heating season. The DHW heating energy demand was 6 kWh/m² [41]. The occupants' internal heat gains were set at a

Buildings 2023, 13, 2670

		Usage	ume	0 a.m4	E p.m. (workdays)
	Annual i	nternal heat gains	of equipment (kWh,	/m²·a)	3.7
	Annual	l internal heat gains	s of lighting (kWh/n	n²∙a)	18.3
	Act	tual peak heating p	ower demand (kW)		113.2
Buildings 2023 , 13, 2670	Table 6 sl	hows the VAV syst	tem with CO ₂ contro	ol and the CAV sys	9 of 23 tem. The range of
	the airflow co	vers the maximum	n air change rate of	all the rooms in th	e building. Every
	working day, 1.2 MEP activity two hours after 6 a.m. Table 6 sp mine the design lass, and then supply distrigm SO a.m. to exha design supply The lass, Ventice	the ventilation sys ty level with 0.75 ± 2. The building usa hows the VAV system Sheupply and system Sheupply and system Sheupply and system aust more material and exhaust airflo vines were desem	tems ran for two ho 0.25 clo for secentary of the verify morning, the verify material emissions, in with CO2 control a nust airflowrates of the control a control a manual control of the control of the control the control of the control the control of the control the control of the control of the control of the control of the control of the control of the control the control of the control of the control the control of the control of the control of the control the control of the con	ours before openin varivity and norma tillation system ran a.m. to 4 p.m. durin FIN V AC. [43] was not the CAV system. boms in the building opewith standor di standard selected t tion duct system's p standard EN 13779	g and for another clothing during at full speed from workdays. Selected to deter- system's pressure other two for the other two for the athened ing sea- to determine the pressure loss and [44]. The supply
	air temperatur	re of the ventilation Ventilation syst	systems was set at 1	Airflow Rates [43]	operation time
	Mechanical s Table 6. Ventila with CO ₂ cont	supply and exhaust tion system description trol) with 65% heat	t ventilation (VAV	0.35–3 L/s, m ²	
Ventila	tion System	ing rooms	Airflow Rates [43]	Operat	i ónaTime 6 p.m. for
Mechanical supply and ext control) with 65% heat Mechanical supply and ext heat recovery for o	naus Meahnnisa (v . reco with f65%chti naust ventilation (C. ffic e rooms and hal	цррунапф exhaust ng recov ery for offic AV) with 65% lway	ventilation (CAV) 0.35–3 L/s, m ² ce rooms and hall- 0.35–1.5 L/s, m ²	0.35–1 ₆ 5 <u>L/s</u> ₆ m ² .m.	workdays for workdays

2.3.2. DH Substations

2.3.2 DH Substations The original DH substation (substation 1) in Figure 4 describes heat supply to the building wriginal DH substation (substation 1) in Figure 4 describes heat supply to the building without TES.



Figure 4. Original system connection and design temperatures (substation 1).

The design temperatures were set according to the Finnish guidelines [45] and applied to substation 2. Therefore, the maximum and minimum supply temperatures of DH were 90 °C and 70 °C. 43 °C was set as the maximum allowed DH return water temperature. The maximum space heating supply temperature was 45 °C, and the return water temperature was 20 °C. For the ventilation systems, the supply and return water temperatures were 35 °C and 20 °C. 58 °C is the recommended DHW temperature leaving from the heating device to the building [45], and in the whole building DHW system, the water temperature must be at least 55 °C [22].

Figure 5 describes the way in which the supply water temperatures of DH and space heating changed with outdoor temperatures. They were also applied for substation 2. When the outside temperature was 10 $^{\circ}$ C, the heating was turned off.

The layout of substation 2 is shown in Figure 6. A 5 m^3 hot water storage tank with a total height of 2.2 m was installed for building-level demand response. There was one temperature sensor (T1) located at the height of 1.2 m from the bottom to measure the water temperature. There was another sensor (T2) to measure the primary side DH return water temperature.

atures were 35 °C and 20 °C. 58 °C is the recommended DHW temperature leaving from the heating device to the building [45], and in the whole building DHW system, the water temperature must be at least 55 °C [22].

Buildings 2023, 13, 2670

Figure 5 describes the way in which the supply water temperatures of DH and space heating changed with outdoor temperatures. They were also applied for substation 2.23 When the outside temperature was 10 °C, the heating was turned off.



Buildings **2023**, 13, x FOR PEER RE<u>V</u>IEW





t water storage tank with a l response. There was one he bottom to measure the he primary side DH return

Figure 66 System connection and design temperatures with astorage tank and two orthonometer datat exchange rs. (substation 2).

There were two internal heat exchangers (HEXII and HEX2) topper continiting ghteratalsk water with the DHW and the primary DH water. Their UAvelues were constanted with two return water brateschangers (HEXE) and HEXEL of the return water brateschangers (HEXEL ALL OF Sectors and HEXEL) of the return water temperature of DH. Their brates and HEXEL of the return water temperature of DH. Their brates and the return water temperature of DH. Their brates and the return water temperature of DH. Their brates and the return water temperature of DH. Their brates and the return water temperature of DH. Their brates and the return water temperature of DH. Their brates and the return water temperature of DH. Their brates and the return water temperature of DH. Their brates and the return water temperature of DH. Their brates are also and the return water temperature of DH. The return sectors are also as 390 kW.

2.3.3. Simulation Tool and Weather Data 2.3.3. Simulation Tool and Weather Data

This study used IDA Indoor Climate and Energy (IDA ICE) to simulate the DH subthis study used IDA Indoor Climate and Energy (IDA ICE) to simulate the DH substations and the office building [46]. The tool has been validated in accordance with the EN stations and the office building [46]. The tool has been validated in accordance with the EN stations and the office building [46]. The tool has been validated in accordance with the EN stations and the office building [46]. The tool has been validated in accordance with the stations and the office building [46]. The tool has been validated in accordance with the stations and the office building [46]. The tool has been validated in accordance with the station is a statistic stat

This study considered the stratification of the building-level thermal storage. It was simplified to a one-dimensional tank model [51]. A detailed model introduction of the tank has been shown in Ju et al. [52]. Alimohammadisagvand et al. have validated the

in the simulation of basic thermal calculations, infiltration and ventilation etc., to test its accuracy [50].

This study considered the stratification of the building-level thermal storage. It was simplified to a one-dimensional tank model [51]. A detailed model introduction of the tank has been shown in Ju et al. [52]. Alimohammadisagvand et al. have validated the accuracy of the stratified IDA ICE storage tank model [53].

Figure 7 shows the outdoor temperatures of the heating season from October 2021 24 Buildings **2023**, 13, x FOR PEER REVIEW to April 2022 in Espoo, Finland. Hourly weather data were collected from the Finnish

Meteorological Institute [54]. The minimum outdoor temperature was -19.8 °C in January.



Figure 7. Outdoor temperaturessimEspoorFindaddduringsthehedatatinseseason.

3. Demand Response Control Algorithms saddEfnergy Flevekibilityty

This section includes five main patts. According to the isomlatation procees how in in Figure 4, firstly, the control signal svore diffind to determining the representations of space heating and the storage clark A the tend and new porporago land burspace ARAGEN STATES AND A CONTRACT approver to any the second states and states and states and the second states and the second states and the second states and the second states and states explained in Section 3.4. Section 3.4 proposes energy flexibility factors. Section 3.5 lists the simulated simulated cases.

3.1. Demand Response Control Signals 3.1. Demand Response Control Signals The hourly district heat price that was defined in Section 2.2.3 was used for the The hourly district heat price that was defined in Section 2.2.3 was used for the build building heven bristrict heat niechthat was de tinest in age tiank 22 my paratuse start that wildinsufared that the antical printing 24-aip are the ast a fast of anti-term of the printing astrony we teasrumed the data in a similar to the second second to the second second second second second second second second The participation of the second s [53].+ThenpriceTthendarginal of intersting strategy in the standard strategy in the standard strategy in the standard strategy in the standard strategy is the standard strategy in the standard strategy is the standard strategy in the standard strategy is the standard str valuearginal, vande as The marginal reprint geactions the oversitivity details can be be grid shift how fighthe Armangginal wall we ist the MAW law argue each dimethic study. The details can be seen in the ref. [39]. A marginal value of 15 €/MWh was selected in this study

If
$$HEP < HEP_{avr}^{+1,+24}$$
 – marginal value, Then $CS = +1$
Else if $HEP < HEP_{avr}^{+1,+24}$ – marginal value, Then $CS = +1$
Else $CS Else$ if $HEP > HEP_{avr}^{+1,+24}$, Then $CS=-1$
End If Else $CS=0$
(3)

End If

where *HEP* is hourly energy (district heat) price, ϵ /MWh; *HEP*⁺¹⁺²⁴ appris the moving future where *HEP* is hourly energy (district heat) price, ϵ /MWh; *HEP*⁺¹⁺²⁴ appris the moving future 24 h district heat price, ϵ /MWh; *HEP*⁺¹⁺²⁴ appris the moving future

24 h district heat price f/WWhstrict heat price for each price trend. The average price of discharging isster the average district heat Bring for each nuice of an decleasing the of discharging is of charge by with any mereasing price trend. For a decreasing trend, the average price for charging is $94.4 \notin MWh$.

Table 7. Average district heat price of each price trend.

Price Trend	Increasing	Decreasing	Flat	
Average district heat price		04.4	(2.0	

Table 7. Average district heat price of each price trend.

Price Trend	Increasing	Decreasing	Flat
Average district heat price (ϵ /MWh)	57.1	94.4	62.9

Buildings 2023, 13, x FOR PEER REVIEW. Demand Response Control Algorithm of Space Heating

13 of 24

Figure 8 describes the control algorithm for the demand response control of space heating. The hourly indoor air temperatures were controlled by the space heating system. When the price trend was decreasing, the indoor air temperature was set to the minimum air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C). The normal indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C). The normal indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C). The normal indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C). The normal indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C). The normal indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C). The normal indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C). The normal indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C) was flat, and the maximum indoor air temperature setpoint ($T_{SH, min}, 20^{\circ}$ C) was selected for the increasing price trend. Therefore, the space heating mass flow to the Water radiators was adjusted based on these setpoints. Therefore, the space heating mass flow to the water radiators was adjusted based on these setpoints. Therefore, the space heating mass flow to the water radiators was adjusted based on these setpoints. Therefore, the space heating mass flow to the water radiators was adjusted based on these setpoints. Therefore, the space heating mass flow to the water radiators was adjusted based on these setpoints. Therefore, the space heating mass flow to the water radiators was adjusted based on these setpoints. To prevent overheating, $T_{imit, out}$ was set as 0 °C according to Martin's study [55].



Figure 8. Demand response control algorithm for space heating. Figure 8. Demand response control algorithm for space heating.

3.3. Demand Response Control Algorithm for the Thermal Storage Tank 3.3. Demand Response Control Algorithm for the Thermal Storage Tank

Figure 9 presents the demand response control algorithm for the building-level storage Figure 9 presents the demand response control algorithm for the building-level storage tank. When the district heat price was decreasing, the tank temperature dropped to the age tank. When the district heat price was decreasing, the tank temperature dropped to the analytic the tank temperature dropped to the minimum tank temperature setpoint (*Tresmin*), 55 °C. It is the lowest temperature guarantee that the layer's water temperature is always high enough for the DHW supply $\mathcal{B}_{\text{Hermatice}}$ that the layer 8 water temperature is always high english for the DHW stipply. The normal tank temperature setpoint (T_{Hes} , norm), 60 °C was maintained when the presence of the trend was hat. But in period the esting price-trend period, the maximum tank temperature ce trend was flat. During the increasing insign there ind the main with the maximum park to perform the getpainets/ This is menschest lemberationequal the bomge innur and eaupphytomerature (dissurato) dhirgis that bighest demogratus allow a basis and the same and the second s DID vert of even by the people be The ged to the teach sy had in ited by the energy it is a the wed Were atworsensions (ath part TD) see the grave of the terms at the case connected as a there weine aby OFE meturs of Water de Fi2p seet FriguMeho) of the time assured of the means have the memory at here we have the means a set of the second s prilow 430A acid the wards the advert the principal the same as a construction of the sector of the sent to 4 be or ind the Hasting and clance and be an are have low rethan the state out it is goalled as sbature endimitation oppimation in the second states and the second second second second second second second s teaches never statistic in the statistic term and the mass of the respective terms and the reast the rest of the r wasabayerating the pressure that keyeter to be a strein the set of received a new as about a generate the meastleed tank vid additional heat to the tank the setpoint, the pump received a new signal to decrease the mass flow to avoid additional heat to the tank.

These two algorithms were utilized simultaneously to control both the space heating and the storage tank for demand response. Additionally, the peak power-limiting potential provided by the storage tank was examined. It was realized by limiting the DH supply water mass flow.



Figure 9. Demand response controladepoithhurfootltbotstragetatakk.

3.4. EThese two abart thans, were utilized simultaneously to control both the space heating and the storage tank for demand response. Additionally, the peak power-limiting potential Equations (4) and (5) describe the energy flexibility factors. [39]. They were defined provided by the storage tank was examined. It was realized by limiting the DH supply to describe the proportion of charged or discharged energy during the simulated period. A higher *FF*⁺ or a lower *FF*⁻ indicates a more flexible building.

3.4. Energy Flexibility Factors

Equations (4) and (5) describe IHe^{t} energy flexibility factors [39]. They were defined to(4) describe the proportion of charged or discharge P_{en} and P_{en} during the simulated period. A higher FF^+ or a lower FF^- indicates a more flexible building.

$$FF^{-} = \frac{f_{0}^{-} \left(\frac{P_{ref} - P_{discharging}}{P_{charging} - P_{ref}} \right) \cdot dt}{\int_{0}^{T} \frac{P_{ref} - P_{discharging}}{P_{ref} \cdot dt}}{\int_{0}^{T} \frac{P_{ref} - dt}{P_{ref} \cdot dt}}$$
(4)

where FF^* is the ratio of charged energy during the simulated period compared with a reference case without demand response that is the charging actions, kW; P_{ref} is the hourly heating power with demand response charging actions, kW; P_{ref} is the hourly heating power without demand response, kW; $P_{discharging}$ is the heating power with demand response, kW; $P_{discharging}$ is the heating power with demand response, kW; $P_{discharging}$ is the heating power with demand response, kW; $P_{discharging}$ is the heating power with demand response, kW; $P_{discharging}$ is the heating power with demand response, the hours of the simulation period, h; $P_{discharging}$ power without demand response, kW; $P_{discharging}$ is the heating power with demand response, kW; $P_{discharging}$ is the heating power with demand response, kW; $P_{discharging}$ is the heating power with demand response charging actions, kW; P_{ref} is the hourly heating power without demand response, kW; $P_{discharging}$ is the heating power with demand response charging actions, kW; P_{ref} is the hourly heating power without demand response kW; $P_{discharging}$ is the heating power with demand response charging actions, kW; P_{ref} is the hourly heating power without demand response kW; $P_{discharging}$ is the heating power with demand response discharging actions, kW; P_{ref} is the hourly heating power without demand response kW; $P_{discharging}$ is the heating power with demand response discharging actions, kW; P_{ref} is the action of discharge energy. Constant indoor air temperature setpoints of 21 °C and 20 °C without the storage stapk (substation d). They have a storage that charge energy action discharge energy. The first two have constant indoor air temperature setpoints of 21 °C and 20 °C without the storage stapk (substation d) are accessed as a constant tank temperature setpoints of 51 °C (Refs STareff) and was being the preference case has a constant tank temperature setpoints of 51 °C (Refs STareff) a

Buildings 2023, 13, 2670

demand response control of space heating and thermal storage tank was combined with (DR-SH-ST-PL) and without (DR-SH-ST) peak power limiting. 14 of 23

	Table 8. Simulated cases.								
	Indoor And a Indoor	8. Synulaged Tasek		DR of Space	DR of Ther-	Peak Power			
Cases	Indoor Air Setpoint (°C)	Storage Tank Setpoint (°C)	Substation	Heating DR of Space	DR of There al	Limiting Peak Power			
Ref. 21	Setpoi21 (°C)	Setpoint+°C)	1	Heating	Storage	Limiting			
Reff. 20	240		1 1						
Re &T25	2 2 1	55	1 2						
Ref. ST-55 DR-SH	20^{-23}_{-20}	⁵⁵	$\frac{2}{1}$ 1						
DR-ST	221	55- 55)-90 1	2 2		$\sqrt{}$				
DR&SF-PL	221	55 -590_90	2 2		$\sqrt{\sqrt{1}}$	$\sqrt{\sqrt{1}}$			
DR-SH-ST DR-SH-ST-PL -DR-SH-ST-PL	20023 20-23 20-23	⁵⁵ -90 55-90 	2 2 2	$\sim \sim $	\sim	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~			

¹ This setpoint represents the highest temperature that the storage tank can reach.

4. Results demand response control of space heating without a storage tank (substation 1), and DR-STWASSULTATED to only information sections and the variation of heat there is a storage tank (substation of heat the is a storage tank (substation of heat there is a storage tank (substati

4.1. Here Fuerges Geven introduction of heat reperson costs and reperson costs and reperson to an energy consumption of the strict section of the section of



Figure 10. Delivered heating power during the heating season of ference case Ref 121.

Table 9 collects the maximum DH heating power demand, heat energy consumption, district heat energy cost, power fee, and total district heat cost of simulated cases during the heating season. The district heat energy cost and the power fee were calculated based on the district heat prices (see Figure 2) and Equation (2), separately. The total cost is the sum

of the district heat energy cost and the power fee. The difference of each part compared with Ref. 21 is also listed in the table.

Table 9. Maximum heating power, heat consumption, district heat energy cost, power fee, and total district heat cost of simulated cases.

Cases	Max Heating Power	g Heat Energy Consumption		District Heat Energy Cost		Power Fee		Total Cost	
	(kW)	kWh/m ²	Diff.	€/m ²	Diff.	€/m ²	Diff.	€/m ²	Diff.
Ref. 21	113.2	61.5		5.00		3.47		8.47	
Ref. 20	111.8	57.6	-6.2%	4.70	-6.0%	3.43	-1.2%	8.13	-4.0%
Ref. ST-55	108.3	61.4	-0.2%	4.93	-1.4%	3.33	-4.0%	8.26	-2.5%
DR-SH	112.8	60.6	-1.4%	4.52	-9.6%	3.45	-0.6%	7.97	-5.9%
DR-ST	112.4	62.6	1.9%	4.83	-3.4%	3.44	-0.9%	8.27	-2.4%
DR-ST-PL	64.2	62.4	1.5%	4.85	-3.0%	2.04	-41.2%	6.89	-18.7%
DR-SH-ST	112.4	61.7	0.4%	4.36	-12.8%	3.44	-0.9%	7.80	-7.9%
DR-SH-ST-PL	64.2	61.2	-0.4%	4.53	-9.4%	2.04	-41.2%	6.57	-22.4%

Decreasing the indoor air temperature setpoint by 1 °C (Ref. 20) reduces peak power and saves heat energy consumption and district heat energy cost by about 6%. The demand response control case for space heating (DR-SH) cuts the district heat energy cost by 9.6% compared with Ref. 21. In addition, the indoor temperatures were not always 20 °C in the demand response cases, as they were in Ref. 20. Excluding the cost caused by the indoor air temperature decrease (6.2%, see Ref. 20), there were net savings of 3.4% by demand response.

Compared with Ref. 21, the demand response control of the building-level storage tank (DR-ST) saves 3.4% of the district heat energy cost. Although, compared with Ref. ST-55, it cuts an additional 2% of the district heat energy cost, and the maximum heating power increases with a higher power fee. However, this was mitigated when peak power limiting was utilized in DR-ST-PL. The maximum heating power is limited to 64.2 kW, which means that only 57% of the peak heating power (compared with the dimensioning power, 113.2 kW) is allowed to be used for heat supply. With a sacrifice of only 0.4% of the district heat energy cost, the power fee is cut by 41.2%, and the total cost savings are 18.7%. The power fee decreases from $8257 \notin$ to $4863 \notin$. In addition, it illustrates that peak power limiting has almost no impact on savings by the demand response control of the storage tank.

It shows that the demand response control of space heating (DR-SH) cuts heat energy consumption by 1.4%. The total discharging hours during the simulated period was four times more than the number of charging hours (see Table 10). Therefore, the reduction was caused by decreasing the indoor air temperature setpoint to 20 °C for discharging. However, the demand response control for the building-level storage tank (DR-ST) increases consumption by 1.9%. Different from the demand response control of space heating, the indoor air temperature setpoints remain the same as with the reference cases (Ref. 21 and Ref. ST-55). Changing the tank temperature setpoints from 55 °C to 60 °C or even higher for charging actions causes more heat losses.

Table 10. The number of hours taken up by the setpoints of space heating and the building-level storage tank.

	Indoor Air Temperature			Building-Level Storage Tank		
Setpoints (°C)	Discharging (Min 20)	Normal 21	Charging (Max 23)	Discharging (Min 55)	Normal 60	Charging (Max 90)
Number of hours Total	2393	2123 5089	573	2393	1623 5089	1073

When employing the demand response control of both space heating and the storage tank (DR-SH-ST), it results in the highest district heat energy cost savings, 12.8%. After the application of peaking power limiting (DR-SH-ST-PL), although there is a compromise in the district heat energy cost savings (from 12.8% to 9.4%), the power fee is reduced by 41.2%. Therefore, the highest total cost savings are 22.4%.

4.2. Energy Flexibility

Table 10 collects the number of hours taken up by the setpoints of space heating and the building-level storage tank during the heating season. The hours of indoor air temperature setpoints for charging are about half of the hours to charge the storage tank. The reason is that there was the limiting outdoor temperature to avoid overheating for the demand response control of space heating (see Figure 8). Therefore, it causes the number of hours of indoor air temperature setpoints at 20 °C to be four times higher than that at 23 °C. Moreover, there are 1073 charging hours for the demand response control of the storage tank. The total discharging hours during the simulated period are more than twice the number of charging hours.

Table 11 lists the energy flexibility factors. Since the total discharging hours during the simulated period were four times more numerous than that of the charging hours, more energy was discharged by the demand response of space heating (DR-SH). In addition, its FF^+ value is higher than that of the demand response of the building-level storage tank (DR-ST) because of the larger storage capacity. The reason for a lower FF^- value of the case DR-ST is the same. Since the maximum tank charging setpoint was 90 °C while there was only a 5 °C of temperature drop for discharging actions (from the normal setpoint 60 °C to 55 °C), the amount of discharging energy was less than that of charging with the demand response of the storage tank (DR-ST). FF^+ increases to 19.0% when applying the demand response control of both space heating and the storage tank (DR-ST). Meanwhile, the FF^- decreases to 19.3%. Thus, it becomes more flexible.

Table 11. Energy flexibility factors.

Cases	DR-SH	DR-ST	DR-ST-PL	DR-SH-ST	DR-SH-ST-PL
FF ⁺	10.3%	8.4%	7.5%	19.0%	12.5%
FF^-	-14.2%	-4.6%	-4.3%	-19.3%	-15.9%

Peak power limiting sightly limits the energy flexibility of the demand response control of the storage tank (DR-ST-PL). However, when it was employed in DR-SH-ST-PL, with the demand response control of space heating and the storage tank, the FF^+ value decreases by 6.5%, and the FF^- factor is cut by 3.4%.

4.3. Indoor Air Temperature and Ventilation Conditions

Table 12 collects the number of hours and degree hours below 20 °C and 21 °C during the heating season of the office building's coldest room. It is a meeting room that has the lowest minimum indoor air temperature compared to the other rooms. For Ref. 20, there are 126 h (2.5%) when the indoor air temperature is below 20 °C. For DR-SH, DR-SH-ST, and DR-SH-ST-PL, which used the demand response control of space heating, there are only six or seven hours when the indoor air temperature is under 20 °C. There are only one or two degree hours.

Discharging actions in the demand response control of space heating (DR-SH) increases the number of hours of indoor air temperatures below 21 °C. Oppositely, the demand response control of the storage tank (DR-ST) slightly reduces the number of hours when the indoor air temperatures are below 21 °C because the indoor air temperature setpoint in DR-ST was the same with Ref. 21, 21 °C. Only the tank temperature setpoint increased for charging. After peak power limiting (DR-ST-PL, DR-SH-ST-PL), there are more hours when the indoor air temperature drops below 21 °C.

 ~-	••	

Hours below (h)		Degree Hours	Degree Hours below (°Ch)	
20 °C	21 °C	20 °C	21 °C	
0	354	0	86	
126	4725	22	3113 17 of 23	
0	279	0	71	
7	2457	2	1082	
	Hours b 20 °C 0 126 0 7	Hours below (h) 20 °C 21 °C 0 354 126 4725 0 279 7 2457	Hours below (h) Degree Hours 20 °C 21 °C 20 °C 0 354 0 126 4725 22 0 279 0 7 2457 2	

Table 12) Rh& Thumber of hours and degree hours 268 ow 20 °C and 21 OC during the heat frag season.

DR_ST_PI	0	313	0	76
DR-SH-ST	Hou	rs below (h) 2324	Degree H	ours below 1026
DR-SH-ST-PL	20 °Ç	21 ₂ 4 9 ₅	20 °C	21089
Ref. 21	0	354	0	86
DReth20roing	actions 126the	demand r4725mse	control of 22 pace	heating (BRLSH) in-

creases the finance of hours of indoor air temperatures below 21 °C. Opposite 7, the demand response control of the storage tank (DR-ST) slightly reduces the number of hours when the response control of the storage tank (DR-ST) slightly reduces the number of hours when the response control of the storage tank (DR-ST) slightly reduces the number of hours when the response control of the storage tank (DR-ST) slightly reduces the number of hours when the response control of the storage tank (DR-ST) slightly reduces the number of hours when the storage tank (DR-ST-PL) of the storage tank (DR-ST-PL) to the storage tank more hours when the indoor air temperature drops below 21 °C.

Figure 11 presents the heating season duration of indoor air temperatures of the office fitchbulg in concernation.



Figure 11. Duration curves of indoor air temperatures during the heating season.

The minimum temperature is 1955° Constance eldestroop a GR (2000 expanse staring an aver independent in the pendential of the staring and the constance of the staring and the constance of the staring and th

4.4. DHW Temperature and Tank Temperature 4.4. DHW Temperature and Tank Temperature

Figure 12 describes the DHW outlet temperature duration curves during the heating Figure 12 describes the DHW outlet temperature duration curves during the heating season when TES was installed (see Figure 6). The DHW outlet water would then be mixed season when TES was installed (see Figure 6). The DHW outlet water would then be mixed with the cold city water to meet the required DHW temperature.

with the cold city water to meet the reduired DHW temperature. The minimum DHW outlet temperature for the case with the demand response control of the building-level storage tank and peak power limiting (DR-ST-PL) is 58.9 °C. Only for the case with additional DR control of space heating (DR-SH-ST-PL) is the DHW outlet temperature lower than 58 °C (recommended design DHW temperature, Section 2.3.2). The minimum temperature is 49.5 °C and there are 30 h (0.6%) when the DHW outlet temperature is below 58 °C. This happened within the five coldest days during working hours when the minimum outdoor temperature was lower than -15 °C. Since peak power has been limited, there was a lack of heat supply when there demand response charging actions for space heating occurred during these days.

Buildings 2023, 13, 2670



Figure 12. Duration curves of DHW outlet temperatures.

⁵/₆₄ The minimum DHW outlet temperature for the case with the demand response control of the building-level storage tank and peak power limiting (DR-ST-PL) is 58.9 °C. Only for the case with additional DR control of participate heating (DR-SH-ST-PL) is the DHW outlet temperature lower than 58 °C (recommended design DHW temperature, Section 2.3.2). Thé²minimum temperature is 49.5 °C^R and ⁵ there are 30 h (0.6%) when the DHW outlet temperature is below 58 °C. This happened within the five coldest days during working hours when the minimum outdoor temperature was lower than -15 °C. Since peak power has been limited, there was a lack of heat supply when there demand response charging actions for space heating occurred during these days.

Figure 13 shows the task temperature of the case of th



Figure 13. Tank temperature of certul oversand the certure wedge tapping rate to fend book desteweek.

During charging actions with increasing processed of the charging provided with the control strategy of the provided with the control strategy works well for prohibit overheating.

Figure 13. Tank temperature of each layer and the return water temperature for the coldest week. **5. Discussion**

Flexible bharging a time with its crassing price that be the sharging iparic that the part of the sharging iparic that the set of the sharging iparic that the set of the sharging iparic that the set of the sharping iparic that the set of the set of the sharping iparic that the set of the

Large-scale demand response control application and peak power limiting could also be beneficial for DH producers. It could result in more profits, less CO₂ emissions, and improve DH systems' performance. Peak power limiting decreases the need for total generation capacity so that pipes would transport less power from plants to substations. Moreover, pipe sizes could also be reduced for transportation from plants to substations. In addition, since peak power limiting by building-level storage tanks cuts the peak power demand, additional consumers could be added to a DH network. Therefore, DH companies could earn more benefits from new customers and reduce the expenses for new or replaced generators. However, the investment costs required by the thermal storage tank, heat exchangers, and related electronic radiator valves were not taken into account. Therefore, the investment and life cycle costs should be investigated in future analysis.

The building-level storage tank size, sensor locations, and the inlet and outlet height all affect the actual charging capacity for demand response. The change of each factor will finally increase or decrease the heat stored during charging actions so that DH cost savings vary. Thus, a cost-optimal solution needs to be developed in further studies.

In this study, 43 °C was chosen according to the Finnish guideline [45] as the maximum allowed return water temperature of DH. However, it could be different based on the standards of other countries. For example, it could be lower than 40 °C if the supply water temperature is 70 °C [56] as in Germany. The demand response control for the building-level storage tank needs to be adjusted to different standards because the amount of energy that can be charged to the tank is limited by the maximum allowed DH return water temperature.

Related to the health of DHW supply and usage, legionella multiplies in water at temperatures between 25 °C and 45 °C. There is an exponential increase in bacterial sterilization occurring above 49 °C [21]. When the stored DHW temperature is 50 °C, 90% of legionella bacteria die in 10–124 min. When the stored DHW temperature is at 60 °C, 90% of legionella bacteria die in two minutes [57]. According to the Finnish guidelines [45], the DHW temperature leaving the heating device is recommended to be at least 58 °C. The minimum building-level storage tank temperature setpoint and the peak power limiting level were determined to guarantee that the lowest DHW outlet temperature was 58 °C. For DR-SH-ST-PL, the minimum DHW outlet temperature was 49.5 °C. Thus, one solution is not to employ the demand response control of space heating for colder days when the minimum daily outdoor temperature was lower than -15 °C. However, for example, in Denmark, the tap water temperature can be 45 °C [20]. Thus, the temperature setpoint, control strategy, and the peak power-limiting need to be adjusted to different standards.

The building-level storage tank reacted quicker with demand response actions because of less storage capacity compared to the office building's thermal mass. It indicates that when the length of the charging or discharging periods is short, like three or six hours, the demand response of the storage tank performs better. When the charging or discharging periods are longer, the demand response of space heating can take advantage of the price characteristics optimally. In addition, the normal tank temperature setpoint at 60 °C was selected in this study so that there was a 5 °C drop when discharging. It is an adjustable setpoint. There will be a higher temperature difference for the discharging action when increasing it. However, more heat consumption could be needed with more heat losses. A further study could be developed to investigate the relationship between the demand response benefits of a thermal storage tank and changing the normal temperature setpoint.

In this study, radiators were selected for space heating supply. The demand response control of space heating by floor heating gained more cost savings than that by radiators, according to a study by Alimohammadisagvand et al. [58]. The reason is that floor heating can take advantage of a building's thermal mass storage more optimally. Therefore, the demand response control algorithm of space heating proposed in this study might be even more beneficial with floor heating.

The results are related to a specific building type with similar climate conditions and price characteristics as the ones analyzed for DH production mixes in this study. However,

the demand response control algorithms for space heating and the storage tank are general and could be applied in any building types with different climate conditions and prices. The energy flexibility gained is specific for the analyzed office building. It could vary based on building type.

6. Conclusions

In this study, a DH network of the Finnish city of Espoo was modeled to define dynamic district heat prices. The benefits of the two demand response control approaches for a Finnish office building, the demand response control of space heating and the buildinglevel storage tank, were evaluated by comparing them to each other and utilizing them together. A new demand response control strategy was designed to make the most of the storage tank capacity considering dynamic energy prices, variable DH supply water temperatures, and the district heating maximum allowed return water temperature. Detailed conclusions are listed below:

The demand response control of space heating and the thermal storage tank are both beneficial. When employing the demand response control for space heating and the storage tank simultaneously, 12.8% district heat energy cost savings are attained.

In addition, the results indicate that thermal energy storage provides more potential for peak power limiting. The maximum heating power decreases by 43% and the power fee reduces by 41.1%. Employing the demand response control of both space heating and the thermal storage tank with peak power limiting results in the highest total cost savings, 22.3%. Moreover, according to indoor air and ventilation supply air temperatures, peak power limiting effectively reduces peak power without compromising thermal comfort and ventilation heat supply.

The demand response control of space heating provides more energy flexibility than that of the storage tank because of the larger storage capacity. It becomes more flexible when applying the demand response control of both space heating and the storage tank. Peak power limiting slightly limits the energy flexibility by the demand response control of the storage tank.

The analysis of indoor air temperatures shows that, even for the coldest room of the office building, the demand response control strategies meet the thermal comfort requirement. Therefore, demand response control strategies can be applied without sacrificing the thermal comfort of the building.

Demand response control strategies need to be adjusted according to the DHW supply temperature standard. The minimum DHW supply temperature was 49.5 °C when the demand response control of space heating and the building-level storage tank was utilized with peak power limiting. This happened within the five coldest days during working hours when the minimum outdoor temperature was lower than -15 °C.

Author Contributions: Conceptualization, Y.J., J.J. and R.K.; methodology, Y.J., P.H., J.J. and R.K.; software, Y.J., P.H., J.J. and R.K.; validation, Y.J., J.J. and R.K.; formal analysis, Y.J.; investigation, Y.J.; resources, J.J. and R.K.; data curation, J.J. and R.K.; writing—original draft preparation, Y.J. and P.H.; writing—review and editing, P.H., J.J., R.K. and S.S.; visualization, Y.J.; supervision, R.K.; project administration, R.K.; funding acquisition, R.K. and J.J. All authors have read and agreed to the published version of the manuscript.

Funding: This study is part of FINEST Twins. The FINEST Twins project is funded by the European Union (Horizon 2020 Programme, Grant No. 856602) and the Estonian government. The contributions of Pauli Hiltunen and Sanna Syri are funded by Finnish Academy project ICA-ICT for Climate Action, grant number 342123.

Data Availability Statement: The data presented in this study are shown in the publication.

Acknowledgments: The authors would like to thank Mika Vuolle from Equa Simulation Finland Oy for the fruitful IDA ICE support.

Conflicts of Interest: The authors declare no conflict of interest.

References

- Finnish Energy. Energy Year 2022—District Heating. Available online: http://energia.fi/en/newsroom/publications/energy_ year_2022_-_district_heating.html#material-view (accessed on 3 May 2023).
- Finnish Government. Programme of Prime Minister Sanna Marin's Government 10 December 2019. Inclusive and Competent Finland—A Socially, Economically and Ecologically Sustainable Society. Available online: http://urn.fi/URN:ISBN:978-952-287-811-3 (accessed on 1 July 2021).
- 3. Gelazanskas, L.; Gamage, K.A. Demand side management in smart grid: A review and proposals for future direction. *Sustain. Cities Soc.* **2014**, *11*, 22–30. [CrossRef]
- Ju, Y.; Lindholm, J.; Verbeck, M.; Jokisalo, J.; Kosonen, R.; Janßen, P.; Li, Y.; Kosonen, R.; Schäfers, H.; Nord, N. Cost savings and CO₂ emissions reduction potential in the German district heating system with demand response. *Sci. Technol. Built Environ.* 2022, 28, 255–274. [CrossRef]
- 5. Le Dréau, J.; Heiselberg, P. Energy flexibility of residential buildings using short term heat storage in the thermal mass. *Energy* **2016**, *111*, 991–1002. [CrossRef]
- 6. Reynders, G.; Diriken, J.; Saelens, D. Generic characterization method for energy flexibility: Applied to structural thermal storage in residential buildings. *Appl. Energy* **2017**, *198*, 192–202. [CrossRef]
- 7. Hedegaard, R.E.; Kristensen, M.H.; Pedersen, T.H.; Brun, A.; Petersen, S. Bottom-up modelling methodology for urban-scale analysis of residential space heating demand response. *Appl. Energy* **2019**, *242*, 181–204. [CrossRef]
- 8. Dominković, D.F.; Gianniou, P.; Münster, M.; Heller, A.; Rode, C. Utilizing thermal building mass for storage in district heating systems: Combined building level simulations and system level optimization. *Energy* **2018**, *153*, 949–966. [CrossRef]
- 9. Guelpa, E.; Verda, V. Thermal energy storage in district heating and cooling systems: A review. *Appl. Energy* **2019**, 252, 113474. [CrossRef]
- 10. Buffa, S.; Fouladfar, M.H.; Franchini, G.; Lozano Gabarre, I.; Andrés Chicote, M. Advanced control and fault detection strategies for district heating and cooling systems—A review. *Appl. Sci.* **2021**, *11*, 455. [CrossRef]
- 11. Jebamalai, J.M.; Marlein, K.; Laverge, J. Influence of centralized and distributed thermal energy storage on district heating network design. *Energy* 2020, 202, 117689. [CrossRef]
- 12. Rämä, M.; Wahlroos, M. Introduction of new decentralised renewable heat supply in an existing district heating system. *Energy* **2018**, 154, 68–79. [CrossRef]
- 13. Golmohamadi, H.; Larsen, K.G.; Jensen, P.G.; Hasrat, I.R. Integration of flexibility potentials of district heating systems into electricity markets: A review. *Renew. Sustain. Energy Rev.* 2022, 159, 112200. [CrossRef]
- 14. Benalcazar, P. Optimal sizing of thermal energy storage systems for CHP plants considering specific investment costs: A case study. *Energy* **2021**, 234, 121323. [CrossRef]
- 15. Tan, J.; Wu, Q.; Zhang, M. Strategic investment for district heating systems participating in energy and reserve markets using heat flexibility. *Int. J. Electr. Power Energy Syst.* **2022**, 137, 107819. [CrossRef]
- Doračić, B.; Pavičević, M.; Pukšec, T.; Duić, N. Bidding strategies for excess heat producers participating in a local wholesale heat market. *Energy Rep.* 2022, *8*, 3692–3703. [CrossRef]
- 17. Moser, S.; Puschnigg, S.; Rodin, V. Designing the Heat Merit Order to determine the value of industrial waste heat for district heating systems. *Energy* **2020**, *200*, 117579. [CrossRef]
- Liu, W.; Klip, D.; Zappa, W.; Jelles, S.; Kramer, G.J.; van den Broek, M. The marginal-cost pricing for a competitive wholesale district heating market: A case study in the Netherlands. *Energy* 2019, 189, 116367. [CrossRef]
- Cai, H.; Ziras, C.; You, S.; Li, R.; Honoré, K.; Bindner, H.W. Demand side management in urban district heating networks. *Appl. Energy* 2018, 230, 506–518. [CrossRef]
- 20. Arabkoohsar, A. Non-uniform temperature district heating system with decentralized heat pumps and standalone storage tanks. *Energy* **2019**, *170*, 931–941. [CrossRef]
- 21. Armstrong, P.; Ager, D.; Thompson, I.; McCulloch, M. Domestic hot water storage: Balancing thermal and sanitary performance. *Energy Policy* **2014**, *68*, 334–339. [CrossRef]
- FINLEX. Ympäristöministeriön Asetus Rakennusten Vesi- Ja Viemärilaitteistoista (Decree 1047/2017 Ministry of the Environment's Decree on Water and Sewage Systems in Buildings). Available online: https://www.finlex.fi/fi/laki/alkup/2017/20171047 (accessed on 4 June 2023).
- 23. Buffa, S.; Soppelsa, A.; Pipiciello, M.; Henze, G.; Fedrizzi, R. Fifth-generation district heating and cooling substations: Demand response with artificial neural network-based model predictive control. *Energies* **2020**, *13*, 4339. [CrossRef]
- 24. Knudsen, M.D.; Petersen, S. Model predictive control for demand response of domestic hot water preparation in ultra-low temperature district heating systems. *Energy Build.* **2017**, *146*, 55–64. [CrossRef]
- 25. Difs, K.; Trygg, L. Pricing district heating by marginal cost. *Energy Policy* **2009**, *37*, 606–616. [CrossRef]
- 26. EMD International A/S. "EnergyPRO". Available online: https://www.emd.dk/energypro/. (accessed on 10 February 2020).
- 27. Nordpool. "Historical Market Data". Available online: https://www.nordpoolgroup.com/historical-market-data/ (accessed on 1 October 2021).
- 28. Finnish Energy Ltd. "Kaukolämpötilasto 2019 (Document in Finnish: District Heating in Finland 2019)". Available online: https://energia.fi/files/5384/Kaukolampotilasto_2019.pdf (accessed on 9 December 2021).

- 29. Helen Ltd. "Käyttöveden Lämmityksen Hinta (The Price of Hot Water Heating)". Available online: https://www.helen.fi/lammitys-ja-jaahdytys/kaukolampo/hinnat/kayttoveden-lammityksen-hinta (accessed on 21 September 2023).
- Finnish Meteorological Institute. Lämmitystarveluku eli Astepäiväluku (Heating Demand Figure, i.e., Degree Day Figure). Available online: https://www.ilmatieteenlaitos.fi/lammitystarveluvut (accessed on 18 September 2023).
- energyPRO. User'guide. Available online: https://www.emd-international.com/energyPRO/Tutorials%20and%20How%20To% 20Guides/energyPROHlpEng-4.5%20Nov.%2017.pdf (accessed on 21 September 2023).
- Fortum—Utilising Waste Heat with 2 Unitop 50 FY Heat Pumps. Available online: https://www.friotherm.com/wp-content/ uploads/2017/11/E10-15_Suomenoja.pdf (accessed on 21 September 2023).
- Caruna, O. Suurjännitteisen Jakeluverkon Verkkopalvelu-Ja Liittymismaksuhinnasto. 1 February 2021. Available online: https: //images.caruna.fi/31575610_caruna_liittymismaksuhinnasto_suurjannite_6s_fi_saavutettava.pdf. (accessed on 9 December 2021).
- 34. Trading Economics. EU Carbon Permits. Available online: https://tradingeconomics.com/commodity/carbon (accessed on 9 December 2021).
- 35. Tilastokeskus. Polttoaineluokitus (Fuel Calssification). Available online: https://www.stat.fi/tup/khkinv/khkaasut_.polttoaineluokitus.html (accessed on 19 August 2023).
- 36. Fortum Ltd. Kaukolämmön Hinnat Taloyhtiöille Ja Yrityksille (District Heating Prices for Building Societies and Companies). Available online: https://www.fortum.fi/yrityksille-ja-yhteisoille/lammitys-ja-jaahdytys/kaukolampo/kaukolammon-hinnattaloyhtioille-ja-yrityksille (accessed on 15 December 2022).
- SFS-EN 16798-1:2019; Energy Performance of Buildings. Ventilation for Buildings. Part 1: Indoor Environmental Input Parameters for Design and Assessment of Energy Performance of Buildings Addressing Indoor Air Quality, Thermal Environment, Lighting and Acoustics. Module M1-6. Finnish Standards Association (SFS): Helsinki, Finland, 2019.
- Suhonen, J.; Jokisalo, J.; Kosonen, R.; Kauppi, V.; Ju, Y.; Janßen, P. Demand response control of space heating in three different building types in Finland and Germany. *Energies* 2020, 13, 6296. [CrossRef]
- 39. Ju, Y.; Jokisalo, J.; Kosonen, R.; Kauppi, V.; Janßen, P. Analyzing power and energy flexibilities by demand response in district heated buildings in Finland and Germany. *Sci. Technol. Built Environ.* **2021**, 27, 1440–1460. [CrossRef]
- Ministry of the Environment. D3 Finnish Code of Building Regulation. Rakennusten Energiatehokkuus (Energy Efficiency of Buildings). Regulations and Guidelines; Ministry of the Environment: Helsinki, Finland, 1985. (In Finnish)
- 41. Ministry of Environment. Decree of the Ministry of the Environment on the Indoor Climate and Ventilation of New Buildings. Ministry of Environment. Helsinki. Finland. Available online: https://ym.fi/documents/1410903/35099218/Indoor+Climate+ and+Ventilation+of+New+Buildings.pdf/df12cdbf-a038-19cb-4dc6-254c6cc4f1be/Indoor+Climate+and+Ventilation+of+New+ Buildings.pdf?t=1680607494788 (accessed on 9 July 2023).
- SFS-EN-ISO 7730; Ergonomics of the Thermal Environment. Analytical Determination and Interpretation of Thermal Comfort Using Calculation of the PMV and PPD Indices and Local Thermal Comfort Criteria. Finnish Standards Association: Helsinki, Finland, 2006.
- 43. FINVAC (The Finnish Association of HVAC Societies). Opas Ilmanvaihdon Mitoitukseen Muissa Kuin Asuinrakennuksissa (The Guidelines of Ventilation Dimensioning in Other Buildings than Apartment Building). FINVAC. Available online: https://finvac.org/wp-content/uploads/2020/06/Opas_ilmanvaihdon_mitoitukseen_muissa_kuin_asuinrakennuksissa_2017.pdf (accessed on 20 March 2020). (In Finnish)
- 44. *EN 13779:2007;* Ventilation for Non-Residential Buildings–Performance Requirements for Ventilation and Room-Conditioning Systems. The European Committee for Standardization (CEN): Brussels, Belgium, 2007.
- Publication K1/2021. Rakennusten kaukolämmitys-Määräykset ja Ohjeet-Julkaisu K1/2021(District Heating of Buildings-Regulations and Guidelines-Publication K1/2021). Energiateollisuus. Available online: https://lnkd.in/gsyNvwk2 (accessed on 12 August 2022). (In Finnish)
- Sahlin, P. Modelling and Simulation Methods for Modular Continuous Systems in Buildings. Ph.D. Thesis, Royal Institute of Technology, Stockholm, Sweden, 1996. Available online: https://www.equa.se/dncenter/thesis.pdf (accessed on 2 March 2020).
- EQUA Simulation Technology Group. Validation of IDA Indoor Climate and Energy 4.0 with Respect to CEN Standards EN 15255-2007 and EN 15265-2007; EQUA Simulation Technology Group: 2010. Available online: http://www.equaonline.com/ iceuser/CEN_VALIDATION_EN_15255_AND_15265.pdf (accessed on 11 February 2023).
- 48. Bring, A.; Sahlin, P.; Vuolle, M. Models for Building Indoor Climate and Energy Simulation—A Report of IEA SHC Task 22: Building Energy Analysis Tools; IEA: Stockholm, Sweden, 1999.
- EQUA Simulation Technology Group. Validation of IDA Indoor Climate and Energy 4.0 Build 4 with Respect to ANSI/ASHRAE Standard 140-2004, EQAU Simulation Technology Group: 2010. Available online: http://www.equaonline.com/iceuser/ validation/ASHRAE140-2004.pdf (accessed on 11 February 2023).
- Moosberger, S. IDA ICE CIBSE-Validation: Test of IDA Indoor Climate and Energy Version 4.0 according to CIBSE TM33, Issue 3. HTA LUZRN/ZIG: 2007. Available online: http://www.equaonline.com/iceuser/validation/ICE-Validation-CIBSE_TM33.pdf (accessed on 11 February 2023).
- Verda, V.; Colella, F. Primary energy savings through thermal storage in district heating networks. *Energy* 2011, 36, 4278–4286. [CrossRef]
- 52. Ju, Y.; Jokisalo, J.; Kosonen, R. Peak Shaving of a District Heated Office Building with Short-Term Thermal Energy Storage in Finland. *Buildings* **2023**, *13*, 573. [CrossRef]

- 53. Alimohammadisagvand, B.; Jokisalo, J.; Kilpeläinen, S.; Ali, M.; Sirén, K. Cost-optimal thermal energy storage system for a residential building with heat pump heating and demand response control. *Appl. Energy* **2016**, *174*, 275–287. [CrossRef]
- Finnish Meteorological Institute. Weather and Sea—Download Observations. Available online: https://en.ilmatieteenlaitos.fi/ download-observations (accessed on 28 January 2023).
- Martin, K. Demand Response of Heating and Ventilation within Educational Office Buildings. Master's Thesis, Aalto University, School of Engineering, Department of Energy Technology, HVAC, Espoo, Finland, 2017. Available online: https://aaltodoc.aalto. fi/handle/123456789/29149 (accessed on 4 March 2021).
- Li, H.; Svendsen, S.; Gudmundsson, O.; Kuosa, M.; Rämä, M.; Sipilä, K.; Blesl, M.; Broydo, M.; Stehle, M.; Pesch, R.; et al. Annex TS1 Low Temperature District Heating for Future Energy Systems—Final Report—Future Low Temperature District Heating Design Guidebook. *Int. Energy Agency* 2017. Available online: https://core.ac.uk/download/pdf/154332407.pdf (accessed on 11 February 2023).
- Tabatabaei, S.A.; Klein, M. The role of knowledge about user behaviour in demand response management of domestic hot water usage. *Energy Effic.* 2018, 11, 1797–1809. [CrossRef]
- Alimohammadisagvand, B.; Alam, S.; Ali, M.; Degefa, M.; Jokisalo, J.; Sirén, K. Influence of energy demand response actions on thermal comfort and energy cost in electrically heated residential houses. *Indoor Built Environ.* 2017, 26, 298–316. [CrossRef]

Disclaimer/Publisher's Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.